Law (Education) (1934) Departm

Ms SERIES.

G.O. No. 2139

DATED 12 - 10 - 1934.

[Despatch Abstract.]

Educational DEPARTMENT.

Rt 2417/B

Received ..... 192 *Registered* 192

Subject.

Building grant- St.Cecily's High School, Udipi.

ENCLOSURES.
No .....
.....
Spare copies .....

R. C. No. 633 D/34

Station Madras, *Dated the* 29-9-34 192

From (Name) W.Erlam Smith Esq., M.A.,

(Designation) Ag.Director of Public Instruction,

Madras.

To The Secretary to the Government of Madras,

Law Education Department

Sir,

I have the honour to state that the Correspondent of the St.Cecily's High School, Udipi, has applied for a grant towards the construction of a building for the school. The institution which was a middle school has lately been raise to a complete High School and the existing accommodation is inadequate. The management therefore proposes to construct an additional block of building to accommodate th 3 High School classes, providing for a laboratory, Reading room and library, needle work class, office room etc. The cost of the work according to the management's estimate is

is Rs.34,452/-

2. The plans and estimates were referred to the Consulting Architect to Government. He has that the estimate may be accepted for Rs.33,669/-(vide copy of his notes enclosed). therefore recommend that the scheme may be ~~xxxxxx~~ placed in the list of approved works so as to render the management eligible for a grant not exceeding Rs.16,834/- if and when funds become availab provided the conditions of the Grant-in-Aid Code are duly complied with and the suggestions made by the Consulting Architect in his remarks dated 28-9-34 are carried out. I also recommend that necessary provision for the grant may be made in Part II of the Budget Estimate for 1935-36.

Copy of letter dated 28th September 1934 from the Consulting Architect to Government, Chepauk, Madras.

" St.Cecily's Girls High School, Udipi."

*****

The plans and estimates have been examined and the following remarks are offered:-

(1) The design provides verandahs on both sides and a porch which are required to meet local climatic conditions.

(2) The height of the walls in the Upper Floor is 14' - 0" to the bottom of the tie beam 12'- 0" or 12'-6" is sufficient as per Grant-in-Aid Code. Unless the proposed design follows the existing building in these respects to keep up symmetry, it may be reduced to 12'- 6".

(3) Instead of King Post Trusses proposed, King Rod Trusses as specified in Addenda Volume to the M.D.S.S. may be provided if found cheaper.

(4) The sections of wood work require alterations as shown below:-

Name.	Section required.	Section estimated.
Tie beam for trusses	4 " x 5"	4" x 7"
King Post.	4 " x 4"	4" x 6"
Struts	4" x 3"	4" x 4"
Principal Hip rafters	5" x 10"	3½" x 9"
Verandah rafters	2" x 6" to be fished with main rafters.	2" x 5"

(5) The masonry proposed viz Latrine stones in lime mortar mixed with cement appears unnecessary as the pressure is within the safe limit and may be built wholly in lime mortar.

(6) The proportion for cement mortar may be 1 : 3 instead of 1: 2 for plastering.

7. The soil and sub-soil being hard gravelly it may suffice if foundations are taken into 1' -0" into that strata instead of total depth of 5'- 6" proposed. This may be settled during erection.

8. The rates are fair and the estimate amount appears reasonable for the construction proposed with enclosed verandahs.

9. Subject to the above remarks, the estimate may be recommended for sanction for Rs.34,452- 783) = Rs.33,669 or Rs.33,700/-.

Law (Education) Department.

Grant -

Building - St. Cecily's High School for girls, Udi

List of approved works - Included.

Read the following paper:--

1) B from the D.P.I. R.C No.633 D/24 & 29.9.34

ORDER:-No. 2139 dated 12-10- 1934.

MMS

The Government sanction the inclusion, ~~xxx~~ in the list of approved works maintained in pursuance of G.O. - No.572 Law (Education) dated the 10th May 1922 ~~746 Law (Education), dated 17th June 1922~~ of the construction of an addl building for the St. Cecily's High School for Girls, Udipi at an estimated cost of Rs. 33,669/- while this approval does not convey any guarantee of grant, it will render the work eligible for a grant not exceeding Rs. 16,834 under the provisions of the Grant-in-Aid-Code, ~~Code of Regulations for European Scho~~ if and when funds become available, provided that all the conditions prescribed in the Code are duly complied with and the suggestions made by the Consulting Architect to Govt also carried out

DA
10-10-34

Bund
11.10

SKD
10/10.

To the Director of Public Instruction (with reference to his letter No. dated 10-10-34)

" Accountant-General.

Dpd. by Van / Post / Messenger

Dpr.'s initials.

Date 13/10 19